



## 19 INCH RACK EQUIPMENT DIMENSIONAL DATA as specified by BS5954 (1980) and IEC 297 (1975)

Rack opening width:	450mm
Between fixing centre:	465mm
Between rack outer edge faces:	486mm
Recommended equipment front panel width:	483mm (19 inches)
Recommended equipment body width:	449mm (maximum)
1U incremental height:	44.45mm (1.75 inches)

## BS1363/BS4662 DIMENSIONS

